

DECLARATION OF TEST RESULTS

Reaction to fire tests of the product described in this document were carried out at Allianz Teknik Test Laboratories between 29.01.2024 and 31.01.2024. The reaction to fire classification was made in accordance with the scope of EN 13501-1 standard.

The classified product's, "**Flexiva SKY / Luxesbo**", reaction to fire classification is:

Fire Behaviour		Smoke Production		Flaming Droplets
B	-	s	1	, d 0
Reaction to Fire Classification: B-s1,d0				

Manufactured by: Işıl Mühendislik Mak. ve İnş. San. Tic. A.Ş. / Kurtköy mah. Hızır Reis cad. No:9/1 Pendik-İstanbul


Placed on the market by: Işıl Mühendislik Mak. ve İnş. San. Tic. A.Ş. / Kurtköy mah. Hızır Reis cad. No:9/1 Pendik-İstanbul

Test standards: EN 13823:2020+A1:2022, EN ISO 11925-2:2020, EN 13501-1:2018

Reference numbers of test reports: FT-AZTEK-24-004-2-1, FT-AZTEK-24-004-2-2, CS-AZTEK-24-004-2

Erkan ÖZDAĞ
Allianz Teknik Manager

ALLIANZ TEKNİK EARTHQUAKE & FIRE TEST AND TRAINING CENTER
Türk-Alman Üniversitesi, Şahinkaya Cad. No: 90, 34820 Beykoz / İSTANBUL
Tel: 0216 556 6351 E-mail: allianztechnik@allianz.com.tr
Web: www.allianztechnik.com



This document was prepared upon customer's request, can not be used as a certificate of conformity for any standards. This document is a declaration of test results and does not represent any type of approval or certification of the product. All details of the tested product, field of application and validity of the reports are described in classification report numbered as "CS-AZTEK-24-004-2".